

SCHOOL NAME: School #195 186 E. North St 52 outlets

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
1	S23561.01	4/23/2021	Kitchen Sink	Faucet	Initial	0.001	5/3/2021	N/A
2	S23561.02	4/23/2021	Kitchen Auto Sprayer	Sprayer	Initial	<0.001	5/3/2021	N/A
3	S23561.03	4/23/2021	Kitchen Sink	Faucet	Initial	<0.001	5/3/2021	N/A
4	S23561.04	4/23/2021	Kitchen Sink	Faucet	Initial	<0.001	5/3/2021	N/A
5	S23561.05	4/23/2021	Kitchen Sink	Faucet	Initial	0.002	5/3/2021	N/A
6	S23561.06	4/23/2021	Ground FL Bubbler NR Rm 18	Fountain	Initial	<0.001	5/3/2021	N/A
7	S23561.07	4/23/2021	Fountain by 25	Fountain	Initial	<0.001	5/3/2021	N/A
8	S23561.08	4/23/2021	Clinic 027	Faucet	Initial	<0.001	5/3/2021	N/A
9	S23561.09	4/23/2021	Clinic 027A	Faucet	Initial	0.002	5/3/2021	N/A
10	S23561.10	4/23/2021	Room 28	Faucet	Initial	0.003	5/3/2021	N/A
11	S23561.11	4/23/2021	Room 28	Faucet	Initial	0.003	5/3/2021	N/A
12	S23561.12	4/23/2021	Room 28	Faucet	Initial	0.002	5/3/2021	N/A
13	S23561.13	4/23/2021	Room 28 #4	Faucet	Initial	0.001	5/3/2021	N/A
14	S23561.14	4/23/2021	Bubbler Ground FL Rm 28	Fountain	Initial	0.004	5/3/2021	N/A
15	S23561.15	4/23/2021	Main Locker Area	Fountain	Initial	<0.001	5/3/2021	N/A
16	S23561.16	4/23/2021	Main Locker Area	Fountain	Initial	<0.001	5/3/2021	N/A
17	S23561.17	4/23/2021	Ground FL Rm 001	Faucet	Initial	0.002	5/3/2021	N/A
18	S23561.18	4/23/2021	Ground FL Rm 001	Faucet	Initial	<0.001	5/3/2021	N/A
19	S23561.19	4/23/2021	Ground 003 Home EC	Faucet	Initial	<0.001	5/3/2021	N/A
20	S23561.20	4/23/2021	Ground 003 Home EC	Faucet	Initial	<0.001	5/3/2021	N/A
21	S23561.21	4/23/2021	Ground 003 Home EC	Faucet	Initial	<0.001	5/3/2021	N/A
22	S23561.22	4/23/2021	Ground 003 Home EC	Faucet	Initial	0.003	5/3/2021	N/A
23	S23561.23	4/23/2021	Serving Area Faucet Kitchen	Faucet	Initial	0.003	5/3/2021	N/A
24	S23561.24	4/23/2021	Bubbler Pool	Fountain	Initial	<0.001	5/3/2021	N/A

SCHOOL NAME: School #195 186 E. North St**52 outlets**

Sample ID	Lab ID #	Sample Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mg/L	Lab Report Receipt Date	Action Taken for Outlets Greater than 0.015 mg/L
25	S23561.25	4/23/2021	Basement Hall by B02	Fountain	Initial	<0.001	5/3/2021	N/A
26	S23561.26	4/23/2021	Basement Hall by B02	Fountain	Initial	<0.001	5/3/2021	N/A
27	S23561.27	4/23/2021	1st Floor Guidance Lav Faucet	Faucet	Initial	<0.001	5/3/2021	N/A
28	S23561.28	4/23/2021	1st Floor Bubbler Near Room 108	Fountain	Initial	<0.001	5/3/2021	N/A
29	S23561.29	4/23/2021	1st Floor Fac Rm 115 Vending Machine Rm	Faucet	Initial	0.002	5/3/2021	N/A
30	S23561.30	4/23/2021	115 Mens Lav Faucet	Faucet	Initial	0.005	5/3/2021	N/A
31	S23561.31	4/23/2021	Rm 115 Womens Lav Faucet	Faucet	Initial	0.002	5/3/2021	N/A
32	S23561.32	4/23/2021	Fountain by 117	Fountain	Initial	0.001	5/3/2021	N/A
33	S23561.33	4/23/2021	Room 117 Faucet	Faucet	Initial	<0.001	5/3/2021	N/A
34	S23561.34	4/23/2021	Main Room 101	Faucet	Initial	<0.001	5/3/2021	N/A
35	S23561.35	4/23/2021	Main Office Rm 100 Restroom	Faucet	Initial	0.003	5/3/2021	N/A
36	S23561.36	4/23/2021	Room 104 Faucet	Faucet	Initial	0.003	5/3/2021	N/A
37	S23561.37	4/23/2021	1st Floor Room 105 Lav Faucet	Faucet	Initial	0.002	5/3/2021	N/A
38	S23561.38	4/23/2021	Hall by 208	Fountain	Initial	<0.001	5/3/2021	N/A
39	S23561.39	4/23/2021	Hall by 208	Fountain	Initial	<0.001	5/3/2021	N/A
40	S23561.40	4/23/2021	2nd Floor New Edition Library	Faucet	Initial	<0.001	5/3/2021	N/A
41	S23561.41	4/23/2021	Hallway Near Rm 215	Fountain	Initial	<0.001	5/3/2021	N/A
42	S23561.42	4/23/2021	Room 213	Faucet	Initial	0.009	5/3/2021	N/A
43	S23561.43	4/23/2021	213	Fountain	Initial	0.010	5/3/2021	N/A
44	S23561.44	4/23/2021	Room 218	Faucet	Initial	0.001	5/3/2021	N/A
45	S23561.45	4/23/2021	2nd Floor Old Bldg Hallway Near Rm 222	Fountain	Initial	0.001	5/3/2021	N/A
46	S23561.46	4/23/2021	2nd Floor Faculty Mens Restroom	Faucet	Initial	0.002	5/3/2021	N/A
47	S23561.47	4/23/2021	Faculty Womans	Faucet	Initial	0.003	5/3/2021	N/A
48	S23561.48	4/23/2021	3rd Fl Hallway New Edition (B) Right	Fountain	Initial	<0.001	5/3/2021	N/A

